



VLFT.EX15338 Special System Water Control Valves, Deluge Type

[Page Bottom](#)

Special System Water Control Valves, Deluge Type

[See General Information for Special System Water Control Valves, Deluge Type](#)

FLUID EQUIPMENT INTERNATIONAL LTD

EX15338

14 CHANCERY GATE BUSINESS CENTRE
MANOR HOUSE AVENUE
SOUTHAMPTON, SO15 0AE UNITED KINGDOM

Deluge type valves, Model FDV30 with control trims E2, EM2, E3, EM3, EM3PR, P, PM, EP, EPM, H, HM, EH, EHM, EPD, EPDM rated pressure 375 psig, 2, 2.5, 3, 4, 6, 8 and 10 in. size globe pattern for horizontal or vertical installation. For operation hydraulically, pneumatically, electrically, manually or combinations thereof. Manual and automatic reset. The height of the pilot line above the valve is limited as shown in the manufacturer's installation instructions.

Deluge type Valves, Model FDVA30 with control trims E2, EM2, E3, EM3, EM3PR, P, PM, EP, EPM, H, HM, EH, EHM, EPD, EPDM rated pressure 375 psig, 2, 3, 4, 6, 8 and 10 in. size angle pattern. For operation hydraulically, pneumatically, electrically, manually or combinations thereof. Manual and automatic reset. The height of the pilot line above the valve is limited as shown in the manufacturer's installation instructions.

Deluge type valves, Model FDV10 rated pressure 375 psig 2, 3, 4, 6, 8, and 10 in. size diaphragm type for horizontal or vertical installation. For operation hydraulically, pneumatically, electrically, manually, or combinations thereof. Manual and automatic reset. The height of the pilot line above the valve is limited as shown in the manufacturer's installation instructions.

Pressure Regulating Deluge Valves, Model FPDV30 with control trims E2, E3, P, EP, H, EH rated pressure 375 psig in 2, 3, 4 and 6 in sizes with a globe pattern for horizontal or vertical installation. For operation hydraulically, pneumatically, electrically, manually or combinations thereof. Manual and automatic reset. The height of the pilot line above the valve is limited as shown in the manufacturer's installation instructions.

Authorities having jurisdiction should be consulted before installation.

[Last Updated](#) on 2015-05-20

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2015 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2015 UL LLC".